IAC Ch 94, p.1

- 875—94.1(89) Scope. This chapter shall apply to:
 - 94.1(1) Steam boilers for operation at pressures not exceeding 15 psig;
- **94.1(2)** Hot water heating boilers for operation at pressures not exceeding 160 psig or temperatures not exceeding 250° F at or near the boiler outlet;

94.1(3) Hot water supply boilers for operation at pressures not exceeding 160 psig or temperatures not exceeding 210° F at or near the boiler outlet.